

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20192096
Address: 940 NW PRYOR RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Robb Popp	Partial	Tuesday, August 18, 2020

Corrective Action Required:

1	Miscellaneous Correction	RETAIL AREA "B"
---	--------------------------	-----------------

-AREAS APPROVED-

-CORRIDOR 103 WEST WALL FROM COLUMN LINE 2 TO 4.4 EXTERIOR SHEATHING SCREW PATTERN

Corrective Action Required:

2	FIRST FLOOR	AREA "E"
---	-------------	----------

-AREAS APPROVED-

RC CHANNEL ROOMS 125,126,127,128,129,133,134,135 WALLS AND CEILING

Corrective Action Required:

3	SECOND FLOOR	AREA "E"
---	--------------	----------

-AREAS APPROVED-

RC CHANNEL CORRIDOR 222
RC CHANNEL CORRIDOR 226 TO ROOM 250
RC CHANNEL WALLS AND CEILING 240,264

Corrective Action Required:
4 THIRD FLOOR SCREW PATTERN ON FIRST LAYER WALLS CORRIDOR 219 TO ROOM 241,
CORRIDOR 222 TO STAIRS
AREA "E"

-AREAS APPROVED-

RC CHANNEL WALLS AND CEILINGS 340,364
RC CHANNEL CORRIDOR 322 TO CORRIDOR 326
RC CHANNEL CORRIDOR 326 AND 327

SCREW PATTERN ON CEILING CORRIDOR 322
SCREW PATTERN ON CEILING CORRIDOR 326 TO ROOM 355

Corrective Action Required:
5 FOURTH FLOOR SCREW PATTERN ON FIRST LAYER WALLS CORRIDOR 319 TO ROOM 341,
CORRIDOR 322 TO STAIRS
AREA "E"

-AREAS APPROVED-

RC CHANNEL WALLS AND CEILING 438,462
RC CHANNEL CORRIDOR 422, CORRIDOR 426
RC CHANNEL CORRIDOR 427

SCREW PATTERN ON FIRST LAYER WALLS CORRIDOR 419 TO ROOM 439
SCREW PATTERN ROOMS 439,440,441,442,443,459,460

Comments: