

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20172529
Address: 261 NW KESSLER DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Michael Harkins	Failed	Tuesday, August 18, 2020

Corrective Action Required:

1	Misc	- 109 ANTI TIP DEVICE RANGE, SPRINKLER HEAD PATIO - - G 10 SELF CLOSING DOOR - - FIRE CAULK LOW VOLT ALL GARAGES - - ELECTRICAL ROOM NEXT TO G3 FIRE CAULK CEILING - - LABEL A/C DISCONNECTS - - LABEL MAIN DISCONNECTS - - 2ND STORY STAIRS FIRE CAULK RISER PIPE - - SIDEWALK REAR ENTRANCE - - BUBBLE COVERS - - SEAL EXTERIOR LIGHT FIXTURES - - INSTALL A/C CONDENSORS - - GUARDRAIL AT RETAINING WALL -
---	------	--

Comments: