



August 18, 2020


Summit Homes
120 SE 30th St.
Lee's Summit, MO 64082

RE: Revision of 11' tall foundation wall specification for the suspended garage slab for Lot # 24 Hawthorne Ridge 1513 SW Sugar Tree Dr. Lee's Summit, MO 64082 – Permit # PRRES20201848

This letter addresses the revision to the 11' tall foundation wall specification for the suspended garage slab.

The revisions shall be as follows:

- Specification for 11' tall foundation wall shall be as follows:
 - 10" thick x 11' tall foundation wall with #4 bars @ 12" oc horizontal and #4 @ 6" oc vertical per S2.0 on 24" wide x 8" thick concrete ftg with (2) #4 bars continuous.



Sincerely,

Blake Shadid

Blake Shadid, P.E.

