

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20200307
Address: 3381 NW CHIPMAN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rough Plumbing Inspection - Commercial	Michael Harkins	Partial	Friday, July 17, 2020

Informational:

1	THE FOLLOWING AREAS ARE APPROVED	- ROOF DRAINS STEADY AT 5 PSI 3 GAUGES - - EXCEPT ONE ROOF DRAIN LINE ABOVE RESTROOMS TO CORE DRILL EXISTING WALL NEEDS INSPECTION -
---	----------------------------------	---

Comments: