

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSUBD20191872  
Address:

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>DE - Public Curb Inspection</b>		Partial	Wednesday, August 19, 2020

Informational:

1	Misc	John DiMauro 8/19/2020 8:55 AM
---	------	--------------------------------

JK Concrete is on site installing the public curbs. I have verified the correct concrete mix being used. The practices being used comply. KC Testing lab is on site pulling concrete samples every 50 cubic yards. We will be provided with the testing results.

**Comments:**