

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20201087
Address: 460 NW CHIPMAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underground Plumbing Inspection - Commercial	Michael Harkins	Failed	Wednesday, August 19, 2020

Corrective Action Required:

1	Misc	- RESUBMIT TYPE OF GREASE INTERCEPTOR INSTALLED PLANS SHOW 1000 GAL INSTALLED 250 GAL -
---	------	--

Comments: