

### **PLANS REVIEW CONDITIONS**

Permit No:	PRCOM20200445	Date:	August 19, 2020
Project Title:	MID-CONTINENT PUBLIC LIBRARY - COLBERN ROAD	Applicant:	
Location:		CONLEY SPRINKLER INC	
1000 NE COLBERN RD, LEES SUMMIT, MO 64064		PO BOX 572	
Type of Work:		PLEASANTON, KS 66075	
Occupancy Group:	A-3	Primary:	(913) 352-6344
Description:	NEW LIBRARY		
Construction Type:	Type IIB (Unprotected)		
Map Page:	175V		

**Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.**

#### **Sprinkler Plan Review**

**Reviewed By: Michael Weissenbach**

**Released for Construction**

1. 2018 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

(Informational Purposes)

Call (816)969-1300 to schedule a Hydrostatic test and a Water Flow test.

2. (Informational Purposes)

Update your records showing NFPA 13 2016 edition.

**The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.**