

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20193585  
Address: 2920 NW THOREAU DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Michael Harkins	Failed	Thursday, August 20, 2020

Corrective Action Required:

1	Misc	<ul style="list-style-type: none"><li>- SUBMIT AS GRADED PLOT PLAN -</li><li>- SUBMIT ENGINEER LETTER FROM FAILED ALL ROUGH -</li><li>- STAIR LAYOUT ON DECK DIFFERS FROM PLANS ( DECK PIER PARTIAL PASS) -</li><li>- PROVIDE SOD -</li><li>- COMPLETE PLUMBING FIXTURES -</li><li>- INSTALL DISHWASHER &amp; COOKTOP -</li><li>- SEAL FLOODLIGHT BACK YARD -</li><li>- PROVIDE (2) 3" SCREWS IN EACH EXTERIOR HINGE PATIO DOOR -</li><li>- FLASHING HORIZONTAL TRIM AT GAS METER -</li><li>- OBTAIN LAWN IRRIGATION PERMIT SUBMIT BACKFLOW CERTIFICATION -</li></ul>
---	------	---

Comments: