

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20193705
Address: 2716 NE MCBAIN DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	Khanh Nguyen	Partial	Thursday, August 20, 2020

Corrective Action Required:

1	Misc	-Provide max 10 ft vertical support for PVC. Also provide lateral restraint for PVC in between the required 10 ft support for PVC 2" or smaller -Seal duct joints
---	------	----------------------------------------------------------------------------------------------------------------------------------------------------------------------

****OK TO DROP TILES**

Comments: