

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20193316
Address: 1626 SW BLACKSTONE PL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Patrick Schonfeldt	Failed	Thursday, August 20, 2020

Corrective Action Required:

1	Misc	<ul style="list-style-type: none">- Submit as graded plot plan for review- Obtain lawn irrigation system permit- Complete guardrail and handrail at deck- Solid block between deck stair rises- Dbl joist hanger at deck floor joist and dbl hoist hanger at cantilever header, both over 4' in length
---	------	--

Comments: