

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20201223
Address: 2934 SW ARBOR TREE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Service Inspection - Residential	Patrick Schonfeldt	Failed	Thursday, August 20, 2020

Corrective Action Required:

1	Misc	- Secure flex gas line at fireplace - Support steel gas line per code - Gas pressure at 8 psi, must maintain 10 psi for 15 minutes minimum
---	------	--

Comments: