

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20193580
Address: 920 NW PRYOR RD, Unit:F, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	Mark Harding	Failed	Friday, August 21, 2020

Corrective Action Required:

1	Misc	-- secure and strap all plumbing at mid-story. -install screws in LVL header per engineers specs. -- repair rated wall at plumbing per discussion and schedule as rated assembly inspection.
---	------	--

Comments: