

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20193016
Address:

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|--|----------------|----------|---------------------------|
| DE - Water Line - Construction Inspection | Ronald Paynter | Partial | Saturday, August 22, 2020 |

Informational:

| | | |
|---|------|--|
| 1 | Misc | 8/22/20 Saturday 8:00AM Contractor (ESS) started installation of waterline Line #1 8/21/20. Contractor did not have to lower elevation of 12" water to obtain 18" of clearance from existing 18" HPDE storm sewer (see document pic). This change should be reflected on as built. |
|---|------|--|

Comments: