

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20193102
Address: 1824 SW MERRYMAN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Patrick Schonfeldt	Failed	Monday, August 24, 2020

Corrective Action Required:

1	Misc	<ul style="list-style-type: none">- Security screws, provide (2) 3" screws each exterior hinge and strike plate at back door and hinge side front door- GFCI protection required at laundry receptacle- Cover plate at laundry receptacle required- Secure vanity lights to wall in master bath- Obtain lawn irrigation system permit- Place splashblocks at all downspout and sump pump discharge locations for minimum distance from foundation 36"
---	------	--

Comments: