

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20193693  
Address: 420 NW CHIPMAN RD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Hood/Duct Inspection</b>	Robb Popp	Failed	Monday, August 24, 2020

Corrective Action Required:

1	Miscellaneous Correction	-PROVIDE APPROVED, CITY STAMPED DRAWINGS -COMPLETE WELDS OF ALL PIECES -SEAL HOLES IN WELDS -PROVIDE 100 WATT LIGHT TO INSPECT PIECES ALREADY WELDED TO HOOD
---	-----------------------------	---

**Comments:**