

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20201498
Address: 140 NW MACKENZIE DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Footing Inspection - Residential	Michael Harkins	Failed	Monday, August 24, 2020

Corrective Action Required:

1	Misc	- PLANS ON SITE ARE FLOPPED PLAN WITH NO CITY STAMP - - PROVIDE 3RD PARTY INSPECTION FOR DRILLED PIERS - - COLUMN PAD E 54 X 54 W/ (8) #4 E W - - COLUMN PAD B MISSING BEHIND FRONT STOOP - - UFER GARAGE WALL NEAR FURNACE -
---	------	---

Comments: