CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20200113

Address: 3125 SW BLUE RIBBON ST, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

DE - Sidewalk Inspection John DiMauro Passed Monday, August 24,

2020

Corrective Action Required:

1 Misc PRE POUR INSPECTION

The forms are set and there appears to be sufficient compacted aggregate.

Sections of the forms on the north side of the driveway approach show a cross slope greater than 2.0 percent. I notified Barry, the flat work contractor, to adjust the forms to ensure that the sidewalk will have a cross slope of less

than 1.5 percent to meet ADA compliance.

I will return for a post pour inspection in 5 business days.

Comments: