CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20193580

Address: 920 NW PRYOR RD, Unit:F, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

All Rough Inspection - Mark Harding Failed Tuesday, August 25,

Commercial 2020

Corrective Action Required:

1 Misc -- secure and strap all plumbing at mid-story.

-install screws in LVL header per engineers specs.

-- repair rated wall at plumbing per discussion and schedule as rated assembly

inspection.

Failed MARK HARDING 08/25/2020 9:14 AM

Comments: