

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSITE20193581

Address: 2001 NW SHAMROCK AVE, Unit:IR, LEES SUMMIT, MO 64081
2001 NW SHAMROCK AVE, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
DE - Proof roll parking lot	Ronald Paynter	Passed	Tuesday, August 25, 2020

Informational:

1 Misc

Terracon was present for the proof roll of the sub-grade. Bair had a tandem dump truck with a 20.7 ton load. They are good to proceed with the installation of geo grid and base rock. RP 8-20-20
8-25-20 Terracon was on site for the proof roll. The parking lot has passed the proof roll with a small correction on the north side of the site at the sidewalk.

Comments: