

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20201210
Address: 2924 NW THOREAU DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Miscellaneous Inspection	Michael Harkins	Failed	Wednesday, August 26, 2020

Corrective Action Required:

1	Misc	- PFH GARAGE PORTAL FRAMING ONLY - - COMPLETE NAILING PATTERN SINGLE CAR - - MISSING NAIL STHD14 SINGLE CAR - - CHECK HEADER TO JACK STUD STRAP AT ROUGH IN - - ANCHOR BOLTS SHALL BE IN MIDDLE 1/3 THE WIDTH OF PLATE -
---	------	--

Comments: