

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20193105  
Address: 1505 SW GEORGETOWN DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Patrick Schonfeldt	Failed	Wednesday, August 26, 2020

Corrective Action Required:

1	Misc	<ul style="list-style-type: none"><li>- Access to jacuzzi tub motor required</li><li>- Remove all paint covers from smokes</li><li>- seal along top of meter can and AC disconnect</li><li>- Secure AC electrical whip within 12" of disconnect</li><li>- Inspection will need to be performed at sales office after conversion back to garage before sale for full C of O</li></ul>
---	------	--

Comments: