## CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

## **DEVSERVICES.CITYOFLS.NET**

## **Inspection Summary**

Permit #: PRCOM20201087

Address: 460 NW CHIPMAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

Underground Plumbing Mark Harding Failed Wednesday, August 26,

Inspection - Commercial 2020

Corrective Action Required:

1 Misc - RESUBMIT TYPE OF GREASE INTERCEPTOR INSTALLED PLANS SHOW 1000 GAL

INSTALLED 250 GAL -

PLAN SHOWS 2" VENT THROUGH ROOF, INSTALL PER PLANS AND RESCHEDULE

**Comments:**