

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20193580
Address: 920 NW PRYOR RD, Unit:F, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Mark Harding	Partial	Wednesday, August 26, 2020

Corrective Action Required:

1	Misc	2hr rated wall needs repaired staggering the joints. failedMARK HARDING 08/25/2020 9:16 AM this is the party wall in the SE corner of the unit. 1st layer ok to cover
---	------	--

Comments: