

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20192096  
Address: 940 NW PRYOR RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Rated Assembly Inspection</b>	Mark Harding	Partial	Wednesday, August 26, 2020

Corrective Action Required:

1	Miscellaneous Correction	RETAIL AREA "B"
		-AREAS APPROVED-

-CORRIDOR 103 WEST WALL FROM COLUMN LINE 2 TO 4.4 EXTERIOR SHEATHING SCREW PATTERN

Corrective Action Required:

2	FIRST FLOOR	-AREAS APPROVED- AREA "E"
		RC CHANNEL ROOMS 124,125,126,127,128,129,133,134,135 WALLS AND CEILING UNITS-126

Corrective Action Required:

3	SECOND FLOOR	\-AREAS APPROVED- AREA "E"
		CORRIDORS-RC CHANNEL 222,226 . 1ST LAYER-222,226

SCREW PATTERN ON FIRST & SECOND LAYERS WALLS CORRIDOR 219 TO ROOM 241, CORRIDOR 222 TO STAIRS

Corrective Action Required: 4	THIRD FLOOR	1ST LAYER UNITS: 241,242,243,244,245,262,262,263; 240,264 AREA "E"
		-AREAS APPROVED-
		RC CHANNEL - 340,364 RC CHANNEL CORRIDORS- 322,326,327,
		1ST LAYER CEILING- 322, 326 TO ROOM 355.
		1ST LAYER WALLS CORRIDORS 319 TO ROOM 341,322 TO STAIRS
		SCREW PATTERN ROOMS AND FIRST LAYER CORRIDOR AND DIMISING WALLS: 341,342,343,344,345,361,362,363
Corrective Action Required: 5	FOURTH FLOOR	-AREAS APPROVED- AREA "E" RC CHANNEL WALLS AND CEILING 438-453, 459-462 RC CORRIDOR 422, 426, 427.
		SCREW PATTERN 1ST, 2ND LAYER WALLS CORRIDOR 419 TO ROOM 439 SCREW PATTEN ROOMS AND SECOND LAYER DIMISING WALL 439,440,441,442,443,459,460,461
Corrective Action Required: 6	STAIR TOWER 1	STAIR TOWER "A" AREAS OK: -1ST LAYER SHEATHING TO 3RD FLOOR; -2ND LAYER SHEATHING TO 3RD FLOOR
Corrective Action Required: 7	ELEVATOR 2	ELEVATOR "B"  AREAS OK: -SHEATHING ON NORTH AND SOUTH WALLS (TYPE A)

**Comments:**