



Licensed Professional Engineer  
(Structural Engineer)

**Dennis J. Sieg, P.E.**

Structural Design  
Property Inspections

August 26, 2020

Tom Garrison  
Automated Control Systems

Tom:

I have completed a structural review for the installation of 9 new roof-top HVAC units for the Kohls building located at 1820 NW Chipman Road, Lee's Summit, Missouri. I conclude that the proposed units may be installed without structural modification to the building.

If you have any questions about this finding, feel free to contact me.

Sincerely,

Dennis J. Sieg, P.E.  
MO License No. 021998

8/26/20