

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRRES20200384
Address: 3004 SW ARBORIDGE DR, LEES SUMMIT, MO 64082
Inspected On: Wednesday, August 26, 2020
Inspected By: Patrick Schonfeldt
Expiration Date: 9/23/2020 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Patrick Schonfeldt	Temporary C of O	Wednesday, August 26, 2020

Corrective Action Required:

1	Misc	- Front bedroom window, tempered glass required where glazing is within 24" of either side of the plane of the door in a closed position
---	------	--

OK for TCO