

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20201084  
Address: 1524 SW SUGAR TREE DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                                | Inspector:         | Outcome: | Date:                     |
|--------------------------------------------|--------------------|----------|---------------------------|
| <b>Gas Piping Inspection - Residential</b> | Patrick Schonfeldt | Failed   | Thursday, August 27, 2020 |

Corrective Action Required:  
1 Misc - Secure gas flex line at fireplace

**Comments:**