

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20193693  
Address: 420 NW CHIPMAN RD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Electrical Service Inspection - Commercial</b>	John Morris	Failed	Thursday, August 27, 2020

Corrective Action Required:

1	Misc	Multiple grounding conductors in the same grounding clamp at rod connection. Only one per clamp -Irreversible splice for grounding electrode conductor -2/0 Cu main bonding jumper -Connect all 3 panels together with sets of two 500 kcmil conductors for both grounded and ungrounded conductors
---	------	--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

**Comments:**