

Inspection Summary

Permit #: PRRES20201007, Building Permit - Residential

Address: 128 NW MACKENZIE DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
Driveway Inspection	Steve Robbins	Partial	Thursday, August 27, 2020

Informational

- 1 The approach appeared to have 4 " of compacted rock and appeared to have room for 6" of concrete. There is no sidewalk on this side of the road. They have been approved to pour the approach.

Comments: