

**PUBLIC WORKS ENGINEERING DIVISION**

## Inspection Summary

---

Permit #:PRPWRW20202413, Public Works Right of Way Permit  
Address: 830 NE DOUGLAS ST, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Site Visit Inspection</b>	Matt Munger	Partial	Friday, August 28, 2020

Corrective Action Required

1 Misc

Site visit: the abandonment has taken place, Dave Slaten with LS Water was onsite yesterday to make sure the abandonment was done properly (LS Water Dept. Inspects abandonment). The area that was excavated will need to be graded out and have seed and straw and or sod put down to restore the grass. Will monitor restoration.

**Comments:**