

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRSUBD20192191

Address: 920 NW PRYOR RD, LEES SUMMIT, MO 640811030 NW PRYOR RD, LEES SUMMIT, MO 64081900 NW  
PRYOR RD, LEES SUMMIT, MO 64081940 NW PRYOR RD, LEES SUMMIT, MO 64081840  
NW PRYOR RD, LEES SUMMIT, MO 640811000 NW PRYOR RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>DE - Street - Concrete</b>	Joe Starlin	Partial	Friday, August 28, 2020

Informational:

1	Misc	8/27/20 Thursday 10:55AM Contractor (ESS) began to pouring concrete street Summit Woods and Pryor RD. Testing done by CFS 6.2 on air 83 temperature & 4" slump. See pictures in documents. 8/27/20 Thursday 1:01PM Contractor will complete the North half of the street tomorrow.
---	------	---

Informational:

2	Misc	8/28/20 Friday 9:12AM Contractor (ESS) is pouring the Northside of street to complete worker.
---	------	---

**Comments:**