

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20193693
Address: 420 NW CHIPMAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection - Commercial	John Morris	Passed	Friday, August 28, 2020

Corrective Action Required:

1	Misc	Multiple grounding conductors in the same grounding clamp at rod connection. Only one per clamp -Irreversible splice for grounding electrode conductor -2/0 Cu main bonding jumper -Connect all 3 panels together with sets of two 500 kcmil conductors for both grounded and ungrounded conductors
---	------	--

Comments: