

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20182606
Address: 837 NW DONOVAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Pool Steel/Bonding - Commercial	Robb Popp	Passed	Friday, August 28, 2020

Corrective Action Required:

1	Misc	-BONDING FOR (2) LADDERS, (6) RAILS, POINTS OF SHELL, ADA ARM SWING AND MAT TO POOL EQUIPMENT ROOM
---	------	--

Comments: