

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20191873
Address:

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
DE - Erosion Sediment Control (ESC) Inspection	John DiMauro	Failed	Monday, August 31, 2020

Corrective Action Required:

2	Misc	John DiMauro 8/31/2020 8:25 AM
---	------	--------------------------------

EROSION CONTROL INSPECTION

Install erosion control devices on site according to the ESC PHASE 2 SHEET C.051

Take additional ESC measures that are not called out on the plans in the low lying areas that will allow for silt and sediment to leave the site.

Make these corrections asap.

Comments: