

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20200878
Address: 1717 SW 26TH TER, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Robb Popp	Failed	Monday, August 31, 2020

Corrective Action Required:

1	Miscellaneous Correction	-PROVIDE (2) BOLTS PER CONNECTION IN RIM JOISTS/ POSTS -ENSURE POSTS ARE NOT IN CONTACT WITH THE GROUND OR RATED FOR GROUND CONTACT -NAIL SIDING PER PLANS -REPLACE PORTAL FRAME STUDS THAT ARE NOT FULL LENGTH— LAP SPLICE JOINT WITH 2x4 -STRAP 2" PVC IN PANTRY AT MIDPOINT -ALL 2X6 WALLS TO HAVE DOUBLE KING STUDS PER PLANS -INSTALL EGRESS WINDOWS IN BED 3 & 4 -LAND ELECTRICAL IN BED 3 THAT WAS DISPLACED FOR EGRESS WINDOW FRAMING BED 3
---	--------------------------	--

Comments: