

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20172535  
Address: 269 NW KESSLER DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Rated Assembly Inspection</b>	Michael Harkins	Passed	Thursday, August 27, 2020

Corrective Action Required:

1	Misc	- COMPLETE RC CHANNNEL ELECTRICAL ROOMS - - ALL OTHER AREAS OK TO ROCK -
---	------	---

Corrective Action Required:

2	Misc	GARAGES, CORRIDORS & STAIRWAYS OK TO TAPE ELECTRICAL,IT, RISER ROOMS NEED RC CHANNEL
---	------	---

**Comments:**