

Inspection Summary

Permit #: PRSITE20193581, Development - Site

DCI LEE'S SUMMIT

Address: 2001 NW SHAMROCK AVE, Unit:IR, LEES SUMMIT, MO 640812001 NW SHAMROCK AVE, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
DE - Commercial Curb Inspection	Steve Robbins	Passed	Monday, August 31, 2020

Informational

- 1 The curbs for the parking lot were poured today. They used a 4K mix that was not granite, this is allowed on private curbs. They applied white cure to the curbs and all appears to be good. They are planning on installing asphalt in a few weeks, they did a proofroll for the whole parking lot but it did rain today and is expected to rain tomorrow.

Comments: