

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816) 969-1200 FAX (816) 969-1201

# Temporary Certificate of Occupancy

---

**Permit #:** PRRES20193451  
**Address:** 1405 SW GEORGETOWN DR, LEES SUMMIT, MO 64082  
**Inspected On:** Tuesday, September 01, 2020  
**Inspected By:** Patrick Schonfeldt  
**Expiration Date:** 9/30/2020 12:00:00 AM

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Patrick Schonfeldt	Temporary C of O	Tuesday, September 01, 2020

**Corrective Action Required:**

2	Misc	- Complete final grade and sod - Seal all penetrations in siding - Place splashblocks at all downspout and sump pump discharge locations for minimum distance from foundation 36"
---	------	---

OK for TCO