

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20201389
Address: 2930 SW ARBOR TREE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Patrick Schonfeldt	Failed	Tuesday, September 01, 2020

Corrective Action Required:

- | | | |
|---|------|---|
| 1 | Misc | <ul style="list-style-type: none">- Staple plans together in order- Structural straps required at top and bottom plates bored 50% or more on exterior walls and interior bearing walls- Protection plate at pex for refrigerator in kitchen- Girder truss in garage bearing on form lumber not #2 as per per plans, N side of garage- Truss hangers per plans |
|---|------|---|

Comments: