

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20201084
Address: 1524 SW SUGAR TREE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Patrick Schonfeldt	Failed	Tuesday, September 01, 2020

Corrective Action Required:

1	Misc	- Nail header ends to supporting floor joist at HVAC chase in pantry - (2) 2x10 header above bedroom door and closet door per plans bedroom #5 interior bearing wall - Complete bath fan exhaust 2nd floor bath - Color code UFER ground
---	------	--

Comments: