

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20190654

Address: 2030 NW OBRIEN RD, LEES SUMMIT, MO 640812020 NW OBRIEN RD, LEES SUMMIT, MO 64081500
NW PRYOR RD, LEES SUMMIT, MO 64081450 NW PRYOR RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
DE - Street - Proof Roll	Steve Robbins	Passed	Monday, August 24, 2020

Informational:

1 Misc

Jason from Spalding had a tandem dump truck with a 20.2 ton load. We proof rolled Ashurst and Kaylea. Had 2 spots with minimal pumping. Jason said they will scoop those sections out and replace with additional rock. RP 8-18-20

Informational:

2 Misc

Did a proof roll with a truck that had a ticket with 20.34 tons. The rock had been sitting since last wednesday. The subgrade was very solid and the proof roll passed with no issues.

Comments: