

# Inspection Summary

Permit #: PRSUBD20190654, Development - Subdivision

WOODSIDE RIDGE 1ST PLAT

Address: 2030 NW OBRIEN RD, LEES SUMMIT, MO 640812020 NW OBRIEN RD, LEES SUMMIT, MO  
64081500 NW PRYOR RD, LEES SUMMIT, MO 64081450 NW PRYOR RD, LEES SUMMIT, MO  
64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
DE - Street - Proof Roll	Steve Robbins	Passed	Monday, August 24, 2020

Informational

1 Jason from Spalding had a tandem dump truck with a 20.2 ton load. We proof rolled Ashurst and Kaylea. Had 2 spots with minimal pumping. Jason said they will scoop those sections out and replace with additional rock. RP 8-18-20

Informational

2 Did a proof roll with a truck that had a ticket with 20.34 tons. The rock had been sitting since last wednesday. The subgrade was very solid and the proof roll passed with no issues.

Comments: