CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20193705 Address: 2716 NE MCBAINE DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection	:	Inspector:	Outcome:	Date:
Rated Ass	embly Inspection	Khanh Nguyen	Failed	Wednesday, September 02, 2020
Corrective	Action Required:			
1		-Complete installing type X gb on the unfinished side -Screw to top and bottom track edge @ 8" oc		

Comments: