

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20193315
Address: 222 SW TILLER CT, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Service Inspection - Residential	Patrick Schonfeldt	Failed	Wednesday, September 02, 2020

Corrective Action Required:

1	Misc	- INSTALL INSULATION SHIELD ON B VENT 1ST FLOOR FIREPLACE IN ATTIC - PRESSURIZE GAS LINE FOR TEST, GAUGE AT 0 PSI, MUST MAINTAIN 10 PSI FOR 15 MINUTES
---	------	---

Comments: