CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20200102

Address: 2308 SW CHASE CIR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

Electrical Service Inspection - Patrick Schonfeldt Failed Wednesday,

Residential September 02, 2020

Corrective Action Required:

1 - COLOR CODE/LABEL GROUNDING ELECTRODE CONDUCTOR

Comments: