

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20200268
Address: 2305 SW CHASE CIR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|--|--------------------|----------|----------------------------------|
| Gas Piping Inspection - Residential | Patrick Schonfeldt | Failed | Wednesday, September 02, 2020 |

Corrective Action Required:
1 - SECURE WARD FLEX AT FIREPLACE

Comments: