

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20201007
Address: 128 NW MACKENZIE DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Driveway Inspection	Steve Robbins	Partial	Thursday, August 27, 2020

Informational:

1 Misc

The approach appeared to have 4 " of compacted rock and appeared to have room for 6" of concrete. There is no sidewalk on this side of the road. They have been approved to pour the approach.

Comments: