

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20201007  
Address: 128 NW MACKENZIE DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Driveway Inspection</b>	Ronald Paynter	Passed	Thursday, September 03, 2020

Informational:	
1      Misc	The approach appeared to have 4 " of compacted rock and appeared to have room for 6" of concrete. There is no sidewalk on this side of the road. They have been approved to pour the approach.

Informational:	
2      Misc	Finished driveway meets LS specs. RP 9-2-20

**Comments:**