

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20200990
Address: 1627 SW BLACKSTONE PL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---|--------------------|----------|------------------------------|
| All Rough Inspection - Residential | Patrick Schonfeldt | Failed | Thursday, September 03, 2020 |

Corrective Action Required:
1 - Address rafters landing on blocks - submit engineer letter on fix to devtech@cityofls.net

Comments: