

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20193693
Address: 420 NW CHIPMAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Hood/Duct Inspection	Robb Popp	Partial	Thursday, September 03, 2020

Corrective Action Required:

1	Miscellaneous Correction	-WELD TEST PERFORMED ON GROUND HOOD WHERE EXITS ROOF. RE-INSPECT HOOD ONCE INSTALLED IN PLACE. -FIRST LAYER OF WRAP OK
---	--------------------------	--

Comments: